

CERTIFICATE FOR HEALTH, SANITATION AND DRINKING WATER FACILITIES

Letter no. 272

Dated 11.05.2026

It is certified that an inspection team headed by Food Safety Officer, Puri (M) and MPHS, Puri inspected the said premises of Santoshi English Medium School, at- Sarbodaya Nagar, Puri municipality on 04.05.2026. They inspected the overall sanitary condition of the school campus and drinking water facilities present over there. One no. of water sample was collected and sent to District Public Health Laboratory, Puri for analysis. As per the analysis report, the Drinking water is found to be **Good, Suitable for consumption**. Also, as per the report of MPHS the sanitary condition of the respective school is also **Satisfactory**.

This Certificate is valid for a period of one year.


11.05.26

Health Officer,
Puri Municipality, Puri

**HEALTH OFFICER
PURI MUNICIPALITY, PURI**



Under PPP Mode, Govt. of Odisha.

TEST REPORT

General Manager
WATCO Odisha, Puri

Customer Name & Address: M/s Santoshi English Medium School, Sarboday Nagar, Puri, Odisha	ULR No.: TC1487626000000077F	
	Test Report No.: PR02042026/0084	
Contact Person: Miss. Ellora Baliarsinha	Contact No.: 7978100939	
E.mail ID: santoshisems.puri@gmail.com	Date of Sample Receipt: 02.04.2026	
Type of Sample (Source): Drinking Water (DS).	Sample Quantity (Received): 2.5 Ltr.	
Sampling Location: Sarbodaya Nagar, Puri	Date of Start of Testing: 02.04.2026	
Sample Condition: Proper Packed & details Labeled.	Date of Completion of Test: 04.04.2026	
Sample Submitted at Laboratory By: Customer	Test Report Issue Date: 06.04.2026	
Special Instruction (If Any): No	Sample ID: PR260402/0084	
Customer reference No. & Date: As per Contract.	Total No. of Pages	02
	Page No.	Page 01 of 02

1. (Chemical Testing – Water)

TEST RESULTS

Sr. No.	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)	
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source
1	pH, at 25 °C	IS 3025 (Pt-11), 2022	6.58	6.5 - 8.5	No relaxation
2	Turbidity (NTU)	IS 3025 (Pt-10), 2023	0.42	1 NTU	5 NTU
3	Total Dissolved Solids (mg/L), at 180 °C	IS 3025 (Pt-16), 2023	172	500 mg/L	2000 mg/L
4	Iron (as Fe), mg/L	IS 3025 (Pt-53), 2024 (Cl. 6)	0.02	1.0 mg/L	No relaxation

Note: 1. *BDL-Below Detection Limit.

2. 'Odour' Reported as **Disagreeable** due to presence of RFC content (> 1.0 mg/l) and Odour intensity found Chlorinous.
3. 'Odour' Reported as **Disagreeable** due to Odour intensity found soapy/fishy/pungent/muddy/fruity/alcoholic/oily/fuel/Ammonical/septic/medicinal/paint/vinegar in sample.
4. #Not Done- 'Taste' Parameter not performed due to presence of microbiological contamination in sample.



Reviewed and Authorized By
(Ajit Kumar Sahoo, HOD Chemical)

General Manager
WATCO Odisha, Puri



Under PPP Mode, Govt. of Odisha.

TEST REPORT

General Manager
NAGCO Division, Puri

Customer Name & Address: M/s Santoshi English Medium School, Sarboday Nagar, Puri, Odisha.	ULR No.: TC1487626000000077F	
	Sample ID No.: PR260402/0084	
Special Instruction (If Any): No	Total No. of Pages	02
	Page No.	Page 02 of 02

2. (Biological Testing – Water)

TEST RESULTS

Sr. No.	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)
				Acceptable Limit
1	Coliform (CFU/100 ml)	IS: 15185, 2016	< 1 CFU	Absent/100 ml
2	E.Coli (CFU/100 ml)	IS: 15185, 2016	< 1 CFU	Absent/100 ml

[NOTE- < 1: Not detected in 100ml]

Remarks: 1. Test results are related to the sample submitted by the customer only.
2. Test report refers to the values obtained at the time of testing & results are related to the sample tested as above under the stated condition.
3. The report shall not be reproduced in part / full without written consent of the laboratory.
4. Sample shall be disposed after 7 days of issuance of the Test Report to the customer.

----- End of Report -----



Reviewed and Authorized By
(Meera M. Tripathy, HOD Biological)